



TECHNICAL POLICY

14 – 02 Standpipe Riser Control Valves

Original Issue: February 1985
Revised: April 2006

1. Each standpipe riser is to have a control valve. The valve is to be located within the stair enclosure.
2. All standpipe control valves are to be locked in the open position.
3. Valves that control standpipe mains or risers that supply 20 or more sprinklers are to be monitored by an electric tamper switch.