



## TECHNICAL POLICY

### 13 – 80      Water Flow Switches Connected to Alarm Systems

Original Issue: February 1985  
**Revised: April 2006**

Sprinkler systems in **buildings that have a fire alarm system** shall be connected to that fire alarm system to provide local inside alarm as well as the outside alarm.

Sprinkler systems in **buildings that do not have a fire alarm system** shall have both an inside and outside alarm when the outside alarm horn can not be heard inside the building.