Minneapolis
Health Department

Minneapolis pool concentration chart

		MINIMUM	MAXIMUM
POOLS	Chlorine	2.0 ppm	10.0 ppm
	Bromine	4.0 ppm	15.0 ppm
	PH	7.2	7.8
WHIRLPOOLS	Chlorine	3.0 ppm	10.0 ppm
	Bromine	6.0 ppm	15.0 ppm
	PH	7.2	7.8
WADING POOLS	Chlorine	3.0 ppm	10.0 ppm
	Bromine	6.0 ppm	15.0 ppm
	PH	7.2	7.8

If you need this material in an alternative format please call the Minneapolis Health Department at (612) 673-2301 or email health@minneapolismn.gov.

Deaf and hard-of-hearing persons may use a relay service to call 311 agents at (612) 673-3000. TTY users may call (612) 673-2157 or (612) 673-2626.
Attention: If you have any questions regarding this aterial please call 311 or (612) 673-2301; Hmong - Ceeb toom. Yog koj xav tau kev pab txhais cov xov no rau koj dawb, hu (612) 673-2800; Spanish - Atención. Si desea recibir asistencia gratuita para traducir esta información, llame al teléfono (612) 673-2700; Somali - Ogow. Haddii aad dooneyso in lagaa kaalmeeyo tarjamadda macluumaadkani oo lacag.