



- NOTES:**
- 1 ONE OR MORE GROUND RODS MAY BE REQUIRED
  - 2 PROVIDE PROTECTIVE BUSHINGS ON ALL CONDUITS
  - 3 FOUNDATION TOP SHALL HAVE SQUARED EDGES.
  - 4 ALL FOUNDATION LOCATIONS SHALL BE DETERMINED IN FIELD BY TRAFFIC DIVISION AT TIME OF CONSTRUCTION.
  - 5 CABINET ANCHORS ARE HILTI KWIK BOLT II WEDGE ANCHORS OR EQUAL 4 PER CABINET, 1/2" X 4 1/2" STAINLESS STEEL (#304) FULL THREADED.

NO SCALE

	<b>MINNEAPOLIS</b> DEPARTMENT OF PUBLIC WORKS		FOUNDATION - SIGNAL  SERVICE CABINET	STANDARD PLATE NO. TRAF-1084
	DRAWN: LPK	DATE: 1/1/11		
	APPROVED: DRP	DATE: 1/1/11		